



Declaration of Conformity

For the following equipment :

Product Name: Switching Power Supply

Model Designation: NPX-1200-Y (X=P,B;Y=12,24,48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU) (EU)2015/863

Low Voltage Directive (2014/35/EU) :

EN 62368-1:2014+A11:2017

Dekra certificate : 31-119446

EN 60335-1:2012+A11+A13+A14+A2

Dekra certificate : 31-119443

EN 60335-2-29: 2004+A2:2010+A11:2018

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission EN 55032:2015+A1:2020 Class B

Radiated emission EN 55032:2015+A1:2020 Class A

Harmonic current EN IEC 61000-3-2:2019+A1:2021

Voltage flicker EN 61000-3-3:2013+A1:2019

EMS (Electro-Magnetic Susceptibility)

EN 55024:2010+A1:2015 EN 55035:2017+A11:2020

ESD air EN 61000-4-2:2009 Level 3 8KV

ESD contact EN 61000-4-2:2009 Level 2 4KV

RF field susceptibility EN IEC 61000-4-3:2020 Level 2 3V/m

EFT bursts EN 61000-4-4:2012 Level 2 1KV/5KHz

Surge susceptibility EN 61000-4-5:2014+A1:2017 Level 3 1KV/Line-Line

Surge susceptibility EN 61000-4-5:2014+A1:2017 Level 3 2KV/Line-Earth

Conducted susceptibility EN 61000-4-6:2014 Level 2 3V

Magnetic field immunity EN 61000-4-8:2010 Level 1 1 A/m

EN IEC 61000-4-11:2020

Voltage dip, interruption < 5% residual voltage for 0.5 periods, 70% residual voltage for 25 periods,

< 5% residual voltage for 250 periods.

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number SC1xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D :

(Name / Position)

Aries
(Signature)

Alex Tsai/Director, Product Strategy Center :

(Name / Position)

[Signature]
(Signature)

Taiwan

(Place)

Dec. 5th, 2021

(Date)